

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)
rwtlmoga@gmail.com

TEST REPORT

Name & Address of Customer : Executive Engineer Water Supply and Sanitation Division Faridkot Faridkot		Customer Reference No.	No : Letter No. 5016 Dated : 01/08/2025
		Sample Submitted by	Gursewak singh
		Date of Sample Receipt	02/08/2025
		Analysis Starting Date	02/08/2025
		Analysis completion Date	04/08/2025
Discipline : Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLMOG/2526/00266	Date of Issue :	04/08/2025
Registration no.:	RWTLMOG/REG2526/01601	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Private Submersible Motor Water (Baba Farid Public School Bibi Fatima Block Faridkot) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Faridkot
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mrs. Manju
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Moga

End of the Test Report